





Magnetic coil for contactor Magnetic coil for contactor 3RT504 US:110 V AC 50 Hz screw terminal

product brand name	SIRIUS
product designation	Magnet coil
<b>General technical data</b>	
Substance Prohibitance (day/month/year)	03/01/2017
Net Weight	0.183 kg
type of voltage of the control supply voltage	AC
control supply voltage 1 at AC	
• at 50 Hz rated value	110 V
operating range factor control supply voltage rated value of magnet coil at AC	
• at 50 Hz	0.8 ... 1.1
apparent pick-up power of magnet coil at AC	
• at 50 Hz	270 VA
• at 60 Hz	300 VA
inductive power factor with closing power of the coil	
• at 50 Hz	0.68
• at 60 Hz	0.52
apparent holding power of magnet coil at AC	
• at 50 Hz	22 VA
• at 60 Hz	21 VA
inductive power factor with the holding power of the coil	
• at 50 Hz	0.27
• at 60 Hz	0.29

### Approvals Certificates

Environment	General Product Approval	EMV	other
<a href="#">Environmental Confirmations</a>		 EG-Konf.	 RCM
			<a href="#">Confirmation</a> 

### Further information

Information on the packaging  
<https://support.industry.siemens.com/cs/ww/en/view/109813875>  
 Information for data generation and storage  
<https://support.industry.siemens.com/cs/ww/en/view/109995012>  
 Information- and Downloadcenter (Catalogs, Brochures,...)  
<https://www.siemens.com/ic10>  
 Industry Mall (Online ordering system)  
<https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RT5945-5AF01>  
 Cax online generator  
<https://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RT5945-5AF01>  
 Service&Support (Manuals, Certificates, Characteristics, FAQs,...)  
<https://support.industry.siemens.com/cs/ww/en/ps/3RT5945-5AF01>  
 Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)  
[https://www.automation.siemens.com/bilddb/cax\\_de.aspx?mlfb=3RT5945-5AF01&lang=en](https://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3RT5945-5AF01&lang=en)

last modified: 4/3/2025 