

EUSERC Commercial Metering

Commercial Type BY Meter-Main Combinations



Design/Performance Features

- Outdoor/Indoor—one design for either installation.
- Ring Type—meets requirements for various ring type locking provisions.
- Test Block Bypass Installed—easy servicing without interruption.
- Main Breaker Field Installed—adaptable to the job.
- Main T-Fuse puller factory installed (less fuses)—adaptable to the job.
- Contact local utility to confirm meter socket approval prior to installation

Industry Specifications

- EUSERC – SEC #300
- 240V rated
- 100A and 200A models
- Up to 100,000 AIC when using fuses

2
METER
CENTERS

Ring Type Commercial Meter-Disconnect Combinations with Test Block Bypass

240V AC Max		Tenant Main ^①	CB or Fuse Provision	Service	Jaws	Catalog Number	Service Feed	Dimensions (inches)			KO Fig.	Wire Range AL/CU	Hub Provision
Amps Cont. Duty	Max AIC							Height	Width	Depth			
100	65,000	Circuit Breaker Provision	QP/QPH/HQP	1Phase-3 Wire	4	MM0202L1100EY	OH	37.0	12.5	4.9	BY-1	#6-2/0	RX
				3 Phase-4 Wire	7	MM0303L3100EY	OH	37.0	12.5	4.9	BY-1	#6-2/0	
	100,000	T-Fuse Puller	Class T 300V	1 Phase-3 Wire	4	MM0202F1100EY	OH	37.0	12.5	4.9	BY-1	#6-2/0	RX
						MM0202F1100CEY	OH/UG	24.0	20.2	4.9	BY-3	#6-2/0	
				3Phase-4 Wire	7	MM0303F3100EY	OH	37.0	12.5	4.9	BY-1	#6-2/0	
						MM0303F3100CEY	OH/UG	24.0	20.2	4.9	BY-3	#6-2/0	
200	35,000	Circuit Breaker Provision	QJ2/QJH2/QJ2H/HQJ2H	1 Phase-3 Wire	4	MM0202L1200EY	OH	45.0	14.3	6.4	BY-2	#1/0-250 kcmil	HC
						MM0202L1200CEY	OH/UG	30.0	24.3	6.4	BY-4	#1/0-250 kcmil	
				3 Phase-4 Wire	7	MM0303L3200EY	OH	45.0	14.3	6.4	BY-2	#1/0-250 kcmil	
						MM0303L3200CEY	OH/UG	30.0	24.3	6.4	BY-4	#1/0-250 kcmil	
	100,000	T-Fuse Puller	Class T 300V	1 Phase-3 Wire	4	MM0202F1200EY	OH	45.0	14.3	6.4	BY-2	#1/0-250 kcmil	HC
						MM0202F1200CEY	OH/UG	30.0	24.3	6.4	BY-4	#1/0-250 kcmil	
				3 Phase-4 Wire	7	MM0303F3200EY	OH	45.0	14.3	6.4	BY-2	#1/0-250 kcmil	
						MM0303F3200CEY	OH/UG	30.0	24.3	6.4	BY-4	#1/0-250 kcmil	

Meter
Combinations

① Breaker/fuses not included.